



Goodwill Excel Center - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Goodwill Excel Center PCS	WS-015-001	Break Room	1	In first floor staff lounge			WF-112017-015001-01	4/4/2018	FT-FY18-112017-015001	2.3	<1
Goodwill Excel Center PCS	WS-015-002	Classroom Faucet	1	In classroom 1 in daycare			WF-112017-015002-01	4/4/2018	FT-FY18-112017-015002	4.9	<1
Goodwill Excel Center PCS	WS-015-003	Classroom Faucet	1	In classroom 2 in daycare			WF-112017-015003-01	4/4/2018	FT-FY18-112017-015003	3.0	<1
Goodwill Excel Center PCS	WS-015-004	Classroom Faucet	1	In classroom 3 in daycare			WF-112017-015004-01	4/4/2018	FT-FY18-112017-015004	3.5	<1
Goodwill Excel Center PCS	WS-015-005	Cooler	Basement	In basement lobby	High	Left	WF-112017-015005-01	4/4/2018	FT-FY18-112017-015005	<1	<1
Goodwill Excel Center PCS	WS-015-006	Cooler	Basement	In basement lobby	Low	Right	WF-112017-015006-01	4/4/2018	FT-FY18-112017-015006	<1	<1
Goodwill Excel Center PCS	WS-015-007	Bottle Filler	Basement	In basement lobby	High	Right	WF-112017-015007-01	4/4/2018	FT-FY18-112017-015007	<1	<1
Goodwill Excel Center PCS	WS-015-008	Break Room	Basement	In basement lobby			WF-112017-015008-01	4/4/2018	FT-FY18-112017-015008	3.4	<1
Goodwill Excel Center PCS	WS-015-009	Break Room	Basement	In staff lounge			WF-112017-015009-01	4/4/2018	FT-FY18-112017-015009	1.6	<1